

ADDENDUM NO. 1

TO

CITY OF AUBURN, MAINE
Pavement Resurfacing Project
BID#2025-018

DATE: 1/22/2025

This addendum amends and /or supplements the bid documents as indicated below. Only these items alter the bid documents. Any verbal discussions or responses are hereby declared null and void. Please acknowledge this addendum on the Bid Proposal Form.

Q: Can driveway gravel be placed at the same time as shoulder gravel?

A: Paved driveways can be backed up at the same time as shoulder gravel placement. Gravel driveways all require paved aprons and shall be backed up with gravel immediately after driveway hand pavement is complete.

Q: Do driveways need to have a butt joint ground for matching or is feathering acceptable?

A: Butt joints shall be required on all driveway matches.

Q: When can the Contractor start the work?

A: Work can start on May 5, 2025.

