

ADDENDUM NO. 1
TO
CITY OF AUBURN, MAINE
2025 Reconstruction Project BID#2025-027
DATE: 3/5/2025

This addendum amends and /or supplements the bid documents as indicated below. Only these items alter the bid documents. Any verbal discussions or responses are hereby declared null and void. Please acknowledge this addendum on the Bid Proposal Form.

Q: Is the City going to require the installation of any geotextile fabric between the existing subgrade and the newly installed Type D gravel?

A: No, there is no proposed geotextile fabric for this project.

Q: Are there any sidewalks being reconstructed on Hillsdale Street, or are all newly constructed sidewalks on Granite Street and Davis Avenue?

A: There is no proposed sidewalk on Hillsdale Street. All sidewalks are on Granite Street and Davis Avenue. All existing sidewalks are being reconstructed.

Q: What is the paved width of the newly constructed sidewalks supposed to be?

A: All sidewalks that are being reconstructed shall have a 5-foot finished paved width.



Pre Bid Conference Sign In Sheet

Date: 3/4/2025

BID #2025-027 2025 Reconstruction Project

Company	Representative Name	Contact Number	Email
GENDRON CORP	DAVE SARGENT	440-3415	DAVES@GENDRONCORP.COM
Glidden Ex & Paving	Matt Callahan	609-9592	matt@gliddenpaving.com
GENDRON CORP.	TOMAS FRANSUOZTA	333-7106	TOMAS.F@GENDRONCORP.COM
G.H. STEVENSON	ZACK STEVENSON	685-3600	TKneil@chstevensoninc.com
Coastal Road Repair	Derek Anderson	207-712-3876	danderson@crrme.com
Prattard Sons, Inc	Chad Toothaker	207-345-3311	chad@prattardsons.net
Spencer Group Paving	Dennis Spencer	207-754-5173	dspencers@yahoo.com
Crooker Construction	Jeffrey Gordon	207 595 1850	Jeff@Crooker.com
City Staff Present			
KRIS BENNETT			
CY WILKINSON			

PLEASE PRINT CLEARLY